



City of Chico Fire Department

411 Main Street
Chico, California 95927
Phone: 530.897.3400
Fax: 530.895.4931

Date: 6/16/2022

Subject: Underground fire line permit

Effective July 5, 2022, an underground fire line construction permit will need to be obtained with Chico Fire Department. A Fire Department permit is required for all underground fire line installations with the exception of:

1. NFPA 13D installations where fire sprinkler supply is tapped off of domestic supply line.

WHAT IS ITS PURPOSE?

The purpose of the fire line is to assure that an adequate amount of water from a reliable source is provided for Fire Department use. The permit provides for Fire Department plan review and field inspections, assuring equipment and installation to an acceptable standard.

PERMIT COST?

The cost of a Fire Department permit includes plan review, hydrant location approval and two (2) field inspections.

1. The permit fee for installation of a fire underground supply line is \$496.

WHO CAN APPLY FOR THESE PERMITS?

Only a California-licensed contractor holding a valid license (C16, C34, and C36 may apply for an underground fire line permit to perform the underground fire line installation.

WHO APPROVES THE FIRE DEPARTMENT UNDERGROUND LINE PERMIT?

Plans submitted for permit approval are plan checked and approved by the Fire Department plan reviewer.

WHAT DO YOU SUBMIT?

Plan submittal shall include Fire Department Permit form with appropriate fees, fire flow calculations, and digital plans. Plans must conform to California Fire Code and National Fire Protection Association Standards.

Applications are available online at <https://chico.ca.us/fire-department-forms-documents>
The permit applications and plans may be emailed to firedocs@chicoca.gov.

All installing contractors shall provide proof of a California Contractor's License, a valid Worker's Compensation certificate, and a current City of Chico Business License. The said license and certificate numbers shall be indicated on the permit application prior to submittal of an installation permit.

WHAT OTHER GUIDELINES SHOULD BE FOLLOWED?

1. Fire Hydrants:
 - a. Fire-Flow requirements for buildings: See California Fire Code Amended Appendix B.
 - b. Location/Distribution: See California Fire Code Appendix C
 - c. Identification/Protection: See Section 50 of the California Fire Code.
 - d. Chico City Municipal Code 18R.08.075 Fire hydrants
2. Fire Department Connection: See NFPA 13 NFPA 14.
3. Post Indicator Valve: See NFPA 13.
4. Maintenance/Testing:
 - a. Maintenance: See NFPA 13 and 24.
 - b. Hydrostatic Test: See NFPA 13 and 24.
 - c. Flush: See NFPA 13 and 24.

WHAT ARE THE STEPS?

1. Fill out a Fire Department permit application and email plans to buildingdocs@chicoca.gov with appropriate fees. One set of digital plans and fire flow calculations must also be submitted.
2. Fire Department plan check will be done in fourteen (14) working days. Applicant will be notified of deficiencies by email or the TrakIt program. Deficiencies must be corrected prior to issuance of permit.
3. Approved plans may be picked up or emailed at applicant's discretion.
4. Inspections include a hydrostatic test (200-psi for two (2) hours) and a flush at which time field installation will be reviewed against approved plans and standards. Inspections may be scheduled with TrakIt or by calling (530) 897-3495.
5. If any alteration to an approved system is made during construction, "As Built" plans shall be submitted to the Fire Department for approval.

We look forward to partnering with you to better protect and serve our community.

Respectfully,

Adam Young
Fire Prevention Officer
Chico Fire-Rescue
(530) 897-3400
adam.young@chicoca.gov